



PECHANGA FIRE DEPARTMENT

Crowd Manager Checklist

| | | | |
|---|-----------------------------|------------|---------------|
| EVENT: | FIRE PERMIT #: | | |
| LOCATION: | DATE: | | |
| ADDRESS: | | | |
| <p><i>Trained crowd managers shall be provided for facilities or events where more than 500 persons congregate. Not fewer than two trained crowd managers, and not fewer than one trained crowd manager for each 250 persons or portion thereof, shall be provided for the gathering. Outdoor events with fewer than 1,000 persons in attendance shall not require crowd managers. The number of crowd managers shall be reduced where, in the opinion of the fire code official, the fire protection provided by the facility and the nature of the event warrant a reduction. ~ Pechanga Building & Safety Ordinance (CFC Chapter 4)</i></p> | | | |
| <p>Responsibilities of crowd managers include the items listed below along with any additional items determined by the fire code official based upon the nature of the event.</p> <ol style="list-style-type: none"> 1. Be familiar with emergency operations manual, evacuation plans, primary and secondary exits for event area, and event details. 2. Remain in assigned area for duration of event unless relieved by a qualified crowd manager. 3. Carry flashlight, means of communications, checklist, and copy of PFD permit approval packet on person. 4. Complete pre-event inspection and documentation (checklist provided). 5. Continuously inspect evacuation routes; fire protection systems; special conditions; and fire, electrical, fall/trip, and other potential safety hazards. Remedy hazards immediately. 6. Attempt to extinguish small fires with fire extinguishers if conditions warrant. 7. Report all hazards and emergencies to PRC dispatch. 8. Assist with the evacuation of patrons from event when needed. | | | |
| OCCUPANT LOAD: | # OF CROWD MANAGERS: | | |
| NAMES OF CROWD MANAGERS ASSIGNED TO EVENT: | | | |
| 1. | 5. | | |
| 2. | 6. | | |
| 3. | 7. | | |
| 4. | 8. | | |
| CONDITIONS *Conditions receiving "NO" answers shall be corrected immediately | | YES | NO |
| Does the site (aisles, rows, seating, etc.) match the approved diagram? | | | |
| EXITS | | | |
| Are all exit doors unlocked? | | | |
| Are all exit doors operational? | | | |
| Are all exit signs illuminated and visible? | | | |
| Are all exits, exitways, aisles, stairways, bleachers, etc. clear of all obstructions? | | | |
| Are all BOH corridors, exitways, stairways, etc. clear of all obstructions? | | | |
| FIRE PROTECTION | | | |
| Are all fire alarm notification strobes visible? | | | |
| Are all fire extinguishers visible and accessible? | | | |
| Are standard fire doors (check labels) able to freely self-close and self-latch? | | | |
| Are roll down fire doors able to completely roll down? | | | |
| Are fire lanes accessible for emergency vehicles? | | | |
| SPECIAL CONDITIONS | | | |
| Have pyrotechnics/special effects been approved by the Pechanga Fire Dept.? | | | |
| Have open flames/flame effects been approved by the Pechanga Fire Dept.? | | | |
| Are all decorations flame retardant? | | | |
| Is there a plan for inclement weather? | | | |
| NOTES: | | | |
| NAME OF PERSON COMPLETING FORM (Print): | | | TITLE: |
| SIGNATURE: | | | DATE: |

For questions or concerns, contact Pechanga Fire Dept. 951-770-6045 / 951-770-6010 / 951-770-6001